









Adres:

SZYDŁOWIEC, UL. KOLEJOWA

Wyniki doboru grzejników:

Pomieszczenie	Q	Dobrany grzejnik	L	H	G	Numer katalogowy
	W		[m]	[m]	[m]	
PARTER						
1.2/HALL	1248	CV22-60	1,20	0,60	0,10	
1.4/ZAPLECZE	556	CV22-60	0,60	0,60	0,10	
1.5/SALA KONFERENC.	2370	CV22-60	1,20	0,60	0,10	
1.5/SALA KONFERENC.		CV22-60	1,20	0,60	0,10	
1.5/SALA KONFERENC.	2370	CV22-60	1,20	0,60	0,10	
1.5/SALA KONFERENC.		CV22-60	1,20	0,60	0,10	
1.6/SZATNIA	380	CV22-60	0,40	0,60	0,10	
1.7/WC	465	CV22-60	0,70	0,60	0,10	
1.8/PRZEDSIONEK	463	CV22-60	0,50	0,60	0,10	
1.9/WC	1003	CV22-60	0,70	0,60	0,10	
1.9/WC		CV22-60	0,70	0,60	0,10	
1.10/WC	616	CV22-60	0,90	0,60	0,10	
PIĘTRO						
2.2/HALL	1415	CV22-60	1,40	0,60	0,10	
2.3/POKÓJ ŚNIADAŃ	485	CV22-60	0,50	0,60	0,10	
2.4/POM. BIUROWE	1321	CV22-60	1,40	0,60	0,10	
2.5/POM. BIUROWE	885	CV22-60	0,90	0,60	0,10	
2.6/POM. BIUROWE	1489	CV22-60	1,60	0,60	0,10	
2.8/MAGAZYN	482	CV22-60	0,40	0,60	0,10	
2.9/WC	468	CV22-60	0,70	0,60	0,10	
2.10/PRZEDSIONEK	513	CV22-60	0,50	0,60	0,10	
2.11/WC	1022	CV22-60	0,70	0,60	0,10	
2.11/WC		CV22-60	0,70	0,60	0,10	
2.12/WC	627	CV22-60	0,90	0,60	0,10	

Zestawienie materiałów:

Typ	Symbol	L	H	Numer katalogowy	Ilość	Producent
		[m]	m		[szt.]	
	CV22-60	0,40	0,600		2	
	CV22-60	0,50	0,600		3	
	CV22-60	0,60	0,600		1	
	CV22-60	0,70	0,600		6	
	CV22-60	0,90	0,600		3	
	CV22-60	1,20	0,600		5	
	CV22-60	1,40	0,600		2	
	CV22-60	1,60	0,600		1	